

Chlorine Level Tests in the Morningside Area

Date	Time	Lynn Ave				Comments
		House # 4000	House # 4022	House # 4100	House # 4120	
10/24/07	9:30 AM	0.1 mg/L				bf = before flushing
10/24/07	10:25 AM	.92 mg/L				af = after flushing
10/26/07	3:35 PM	.2 mg/L				bf
10/26/07	4:05 PM	1.32 mg/L				af
10/29/07	3:10 PM	.1 mg/L				bf
10/29/07	3:45 PM	2.2 mg/L				af
10/31/07	9:00 AM	.4 mg/L				bf
10/31/07	9:30 AM	.13 mg/L				af
11/01/07	10:00 AM	.5 mg/L				bf
11/01/07	10:18 AM	2.1 mg/L				af
11/02/07	8:55 AM	.8 mg/L				bf and we ran the hyd all weekend
11/02/07	9:28 AM				2.2 mg/L	bf - temp 55degrees
11/05/07	8:00 AM	1.8 mg/L				ran hyd all weekend w/g-hose Temp 57
11/06/07	10:00 AM	1.0 mg/L				No flush 57 degrees
11/06/06	10:08 AM			2.2 mg/L		Water running continuous 57 degrees
11/07/07	7:39 AM	2.0 mg/L				No flush 57 degrees
11/07/07	7:29 AM			2.2 mg/L		Water running continuous 55 degrees
11/08/07	8:20 AM	1.6 mg/L				No flush 57 degrees
11/08/07	8:30 AM			2.2 mg/L		Running Hyd 55 degrees
11/09/07	9:30 AM			2.2 mg/L		Running Hyd 55 degrees
11/09/07	9:38 AM	1.91 mg/L				No flush 57 degrees
11/13/07	10:36 AM	1.6 mg/L				No flush 55 degrees
11/13/07	10:47 AM			2.2 mg/L		Running Hyd 53 degrees
11/21/07	11:00 AM	1.8 mg/L				No Flush 53 degrees
11/26/07	9:46 AM	2.0mg/L				No Flush 53 degrees
12/06/07	10:20AM	2.1mg/L		2.2mg/L	2.2mg/L	No Flush 47 degrees
12/12/07	10:31AM	1.6mg/L				bf- temp 50 degrees/ Iron/ Shut hydrant off @ 4100 Lynn 3:00 PM on 12/11/07
12/12/07	10:40AM	2.2mg/L				af- temp 46 degrees
12/14/07	11:10AM	1.2mg/L				bf- temp 48 degrees
12/18/07	11:45AM	2.2mg/L				af- temp 45 degrees Turned on Hydrant again @ 4100 Lynn H2O was very discolored when flushing
01/11/08	1:23PM	2.2mg/L				bf- temp 45 degrees
01/11/08	1:27PM			2.2mg/L		Running- temp 45 degrees
01/25/08	1:10PM			2.2mg/L		Running- temp 39 degrees
01/25/08	1:17PM	2.2mg/L				bf- temp 39 degrees
02/25/08	8:35AM	2.2mg/L				af- temp 38 degrees
02/25/08	8:45AM			2.2mg/L		Running- temp 37 degrees
04/07/08	1:35PM			2.2mg/L		Running- temp 39.9 degrees
04/07/08	1:55PM	2.2mg/L				af- temp 39.9 degrees
05/28/08	1:08PM			2.2mg/L		Running-temp 53 degrees
05/28/08	1:36PM	2.2mg/L				af- temp 55 degrees
06/03/08						3,291,330 Gallons used to date

Chlorine Level Tests in the Morningside Area

		Kipling Ave			W 42nd St	Comments
Date	Time	House # 4000	House # 4101	House # 4117	House # 4201	
10/24/2007	10:30 AM	1.2 ml/L				Flushed until clear
10/24/2007	10:50 AM	1.8 ml/L				
10/24/2007	3:50 PM	1.4 ml/L				Flushed until clear
10/24/2007	4:15 PM	2.2 ml/L				
10/24/2007	8:55 AM	1.02 ml/L				ok
11/2/2007	9:05 AM	1.3 mg/L				bf - temp 59
11/2/2007	9:32 AM			2.2 mg/L		bf - temp 55
11/5/2007	8:12 AM	2.2 mg/L				bf - temp 57
11/7/2007	7:50 AM	2.2 mg/L				No flush / 57 degrees
11/7/2007	8:30 AM				2.2 mg/L	No flush / 53 degrees
11/21/2007	11:15AM	2.2mg/L				No flush/ 53 degrees
12/6/2007	10:30AM	2.2mg/L	2.2mg/L		2.2mg/L	No flush/ 47 degrees
12/14/2007	11:20AM	2.0mg/L				bf- temp 46 degrees
1/11/08	1:36PM	2.2mg/L				bf- temp 45 degrees
1/25/2008	1:24PM			2.2mg/L		bf- temp 37 degrees
1/25/2008	1:32PM	2.2mg/L				bf- temp 39 degrees
2/25/2008	8:45AM	2.2mg/L				bf- temp 37 degrees
2/25/2008	8:50AM			2.2mg/L		bf- temp 35 degrees
4/7/2008	2:05PM	2.2mg/L				bf- temp 40 degrees
5/28/2008	1:50PM	2.2mg/L				af- temp 57 degrees

Chlorine Level Tests in the Morningside Area

Date	Time	Grimes Ave		Inglewood Ave		Comments
		House # 4000	House # 4024	House # 4000	House # 4012	
11/2/2007	9:12 AM	2.2 mg/L				bf - temp 57
11/2/2007	9:19 AM			.12 mg/L		bf - temp 60
11/2/2007	9:41 AM			2.2 mg/L		af - temp 57
11/5/2007	8:27 AM			.07 mg/L		bf - temp 60
11/5/2007	8:39 AM			2.2 mg/L		af - temp 57
11/5/2007	8:20 AM	2.2 mg/L				bf - temp 55
11/7/2007	8:15 AM			.4 mg/L		bf - temp 57
11/7/2007	8:25 AM			2.2 mg/L		af - temp 55
11/21/2007	10:35AM	2.2mg/L		.6mg/L		bf- temp 56
11/21/2007	10:40AM			2.2mg/L		af- temp 55
12/6/2007	10:40AM	2.2mg/L				No flush 47 degrees
12/6/2007	10:45AM			.5mg/L		bf - temp 52 degrees
12/6/2007	10:55AM			2.2mg/L		af- temp 47 degrees
12/12/2007	10:16AM			.06mg/L		bf- temp 50 degrees
12/12/2007	10:25AM			2.2mg/L		af-temp 46 degrees
1/11/2008	1:43PM		2.2mg/L			bf- temp 44 degrees
1/11/2008	1:54PM			2.2mg/L		af- temp 45 degrees
1/25/2008	1:40PM	2.2mg/L				bf- temp 39 degrees
1/25/2008	1:55PM			2.2mg/L		af- temp 39 degrees
2/25/2008	9:05AM	2.2mg/L				bf- temp 37 degrees
2/25/2008	9:15AM			2.2mg/L		af- temp 37 degrees
4/7/2008	2:15PM			2.2mg/L		af- temp 40.6 degrees
5/28/2008	2:00PM	2.2mg/L				af- temp 58.5 degrees
5/28/2008	2:11PM			2.2mg/L		af- temp 56.5 degrees